



By Appointment to HM The Queen  
Suppliers of Preserved Timber Fencing

Declaration of Performance No: PSGI

1. Unique identification code of the product type: Imported Pinus Sylvestris (Scots Pine) AC500 Treated Pole
2. Type, Batch or Serial Number – As per customer order reference.
3. Intended use – Structural Timber – Wood Poles for Overhead Lines in accordance with BS EN 14229:2010
4. Saint-Gobain Building Distribution (trading as Calders and Grandidge)  
194 London Road  
Boston  
Lincolnshire  
PE21 7HJ  
UK
5. Mr John Secker – Operations Director  
Address as above
6. System 2+ (CPR Annex V)
7. The notified body BM Trada, Chiltern House, Stocking Lane, Hugheden Valley, High Wycombe, Buckinghamshire, HP14 4ND has performed an initial inspection of the manufacturing plant and of the factory production control and performs continuous surveillance, assessment and approval of our factory production control and has issued certificate of conformity of the factory production control.  
Certificate No: 1224-CPR-0418
8. Declared performance

Essential Characteristics	Levels / Classes		Harmonised Technical Specification – BS EN 14229:2010
	Mean MoR	Ch. Value	
Bending Strength	52.4 Nmm <sup>2</sup>	42.3 Nmm <sup>2</sup>	Tested according to Annex C in May-June 2013 and calculated and declared according to D.3.2 as characteristic value $f_{m,05}$ , (in newtons per square millimetres) or deflection (in millimetres) and load (in kilonewtons)
Modulus of elasticity/Compression Strength	9718 Nmm <sup>2</sup>		Tested according to Annex C in May-June 2013 and calculated and declared according to D.3.3 as characteristic value , $E_{mean}$ , (in newtons per square millimetres) or deflection (in millimetres) and load (in kilonewtons)
Retention	24 kg per m <sup>3</sup>		Tested according to EN 351-2:2007, Clause 4, and declared according to EN 351-1:2007, Clause 5, as retention class.
Penetration	NP5		Tested according to EN 351-2:2007, Clause 4, and declared according to EN 351-1:2007, Clause 5, as penetration class.
Durability Class	4		Declared as Use class 4
Preservative Type	AC500		
Dangerous Substances	NPD		



By Appointment to HM The Queen  
Suppliers of Preserved Timber Fencing

9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Name ...John Secker..... Position ...Operations Director.....

Date ..... 21.10.2019.....Signature 



194 London Road, Boston, Lincolnshire PE21 7HJ • Tel: 01205 358 866 • Fax: 01205 312 400  
enquiries@caldersandgrandidge.com • www.caldersandgrandidge.com

Proprietor: Saint-Gobain Building Distribution Ltd, Saint Gobain House, Harry Weston Rd, Binley Business Park, Coventry CV3 2TT  
Registered in England No. 1647362